

# CERTIFICATE

**TÜV NORD CERT GmbH**  
herewith declares that

**Jiangsu Sunport Power Corp., Ltd.**  
No.20, Xishi Road, Xinwu District,  
Wuxi City, Jiangsu Province, 214028  
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

**Description of product (details see Annex 2):**

**Double Glass PV Modules with 6" Poly-crystalline MWT Solar Cells**



Tested according to: IEC 61215-1:2016;  
IEC 61215-1-1:2016;  
IEC 61215-2:2016;  
IEC 61730-1:2016;  
IEC 61730-2:2016.

Registered No.: 44 780 19 406749 - 215  
Manufacturer: see Annex 1  
Test Report No.: 492010984.002  
File No.: SHV04028/18

Valid from: 2019-07-17  
Valid until: 2023-02-08



TÜV NORD CERT GmbH  
Certification Body  
Consumer Products



Essen, 2019-07-17

Please also pay attention to the information stated overleaf.

**Manufacturer:**

Manufacturer 1: **Nanjing Sunport Power New Energy Co., Ltd.**  
No.28-10, Lanhua Road, Qiaolin Industrial Park, Pukou District,  
Nanjing City, Jiangsu Province, 211806, P.R. China

Factory inspection report no.: 862010246.005

Manufacturer 2: **Xuzhou Sunport Power Co. Ltd.**  
No.1, Fumin Road, High-tech Industrial Development Zone  
Pizhou, Jiangsu Province, P.R. China

Factory inspection report no.: 862010357.003

Manufacturer 3: **Wuxi Sunport Power Co. Ltd.**  
No.12 Xinhua Road, WND,  
Wuxi City, Jiangsu Province, 214028, P.R. China

Factory inspection report no.: 862010442.001

**Remark:**

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



**TÜV NORD CERT GmbH**  
Certification Body  
Consumer Products

**Description of product(s):**

Module types:	<b>Double Glass PV Modules with 6" Poly-crystalline MWT Solar Cells:</b> 72 cells: SPPXXXP72G (XXX=340-375W, in increments of 5) 60 cells: SPPXXXP60G (XXX=280-310W, in increments of 5)
Maximum system voltage:	1500V
Fuse rating:	15A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load:	2400Pa/1600Pa or 2400Pa/2400Pa (downward / upward)*
Safety factors:	1.5
Fire safety class:	Class C

**Remark:**

\*The design load 2400Pa/1600Pa or 2400Pa/2400Pa (downward / upward) has been performed for different installation methods, for detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



**TÜV NORD CERT GmbH**  
Certification Body  
Consumer Products