

# CERTIFICATE

**TÜV NORD CERT GmbH**  
herewith declares that

**Jiangsu Sunport Power Corp., Ltd.**  
No.20, Xishi Road, Xinwu District,  
Wuxi City, Jiangsu Province, 214028  
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

**Description of product (details see Annex 2):**

**Flexible PV module with 6" Mono-crystalline MWT Solar Cells**



Valid from: 2020-08-05

Valid until: 2025-08-04

Tested according to: IEC / EN 61215-1:2016;  
IEC / EN 61215-1-1:2016;  
IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018;  
IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018;  
IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.

Registered No.: 44 780 20 406749 - 145  
Manufacturer: see Annex 1  
Test Report No.: 492011490.001  
File No.: SHV09035/19



**TÜV NORD CERT GmbH**  
Certification Body  
Consumer Products



Essen, 2020-08-05

Please also pay attention to the information stated overleaf.

**Manufacturer:**

Manufacturer 1: **Nanjing Sunport Power New Energy Co., Ltd.**  
No.28-10, Lanhua Road, Qiaolin Industrial Park, Pukou District,  
Nanjing City, Jiangsu Province, 211806, P.R. China

Factory inspection report no.: 862010246.006

Manufacturer 2: **Xuzhou Sunport Power Co. Ltd.**  
No.1, Fumin Road, High-tech Industrial Development Zone  
Pizhou, Jiangsu Province, P.R. China

Factory inspection report no.: 862010357.004

Manufacturer 3: **Wuxi Sunport Power Co. Ltd.**  
No.12 Xinhua Road, WND,  
Wuxi City, Jiangsu Province, 214028, P.R. China

Factory inspection report no.: 862010442.002

**Remark:**

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



**TÜV NORD CERT GmbH**  
Certification Body  
Consumer Products

**Description of product(s):**

Module types:	<b>Flexible PV module with 6" Mono-crystalline MWT Solar Cells:</b> 60 cells: SPPXXXM60S(XXX=305-320W in increments of 5)
Maximum system voltage:	1500V
Fuse rating:	15A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	1600Pa / 1600Pa*
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

**Remark:**

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.

\*Installation method should be added a supporting plate on the back of modules using double-sided tape or industrial structural adhesive, details please refer to installation manual.



**TÜV NORD CERT GmbH**  
Certification Body  
Consumer Products